

**CCA - CENELEC Certification Agreement**  
**Accord de Certification du CENELEC - CENELEC-Zertifizierung-Abkommen**

# NOTIFICATION OF TEST RESULTS

**Product:** Switch-disconnector

**Tested by request of:** OBZOR, výrobní družstvo Zlín  
Na Slanici 378, 764 13 Zlín 4, Czech Republic

**Manufacturer:** OBZOR, výrobní družstvo Zlín  
Na Slanici 378, 764 13 Zlín 4, Czech Republic

**Rating and principal characteristic:** Ith=15, 20, 25 A, Ue=400 V AC, Ui=690 V, 50 Hz, IP 20 (see enclosure)

**Trade name (if any):**

**Model/Type Ref.:** VSN 10, VSN 16, VSN 20

**Additional information (if any):**

A sample of the product has been tested and found to be in conformity with the current HD/EN and equivalent national standard (number and edition):  
EN 60947-3:99+Amd.1:01+Amd.2:05 in conjunction with EN 60947-1:04

as shown in the test report (reference No.): 702401-01/01 of: 09.10.2007

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provision of the relevant specific standard.

This Notification of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983. Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval, as specified in the CCA as long as the standard referred to above is still in force in the country of that body.

This Notification of Test Results may be challenged if it is more than three years old.

Internal ref.: Milan Soběslavský  
Name or initials of contact person

Prague, 9.10.2007



*Kudrna*

Pavel Kudrna  
Certification and Inspection Manager



**ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV**

Pod Lisem 129, 171 02 Praha 8 – Troja, Czech Republic



702401