

NOTIFICATION OF TEST RESULTS

Product: Switch - disconnectors

Tested by request of: OBZOR, výrobní družstvo Zlín
Na Slanici 378, 764 13 Zlín 4, Czech Republic

Manufacturer: OBZOR, výrobní družstvo Zlín
Na Slanici 378, 764 13 Zlín 4, Czech Republic

Rating and principal characteristic: see enclosure - technical data of switch-disconnectors VSN 25-32

Trade name (if any):

Model/Type Ref.: VSN 25, 32

Additional information (if any):

A sample of the product has been tested and found to be in conformity with the current HD/EN and equivalent national standard (number and edition):
EN 60947-1:04, EN 60947-3:99+Amd.1:01+Amd.2:05

as shown in the test report (reference No.): 703402-01/01 of: 26.11.2007

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provision of the relevant specific standard.

This Notification of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983. Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval, as specified in the CCA as long as the standard referred to above is still in force in the country of that body.

This Notification of Test Results may be challenged if it is more than three years old.

Internal ref.: _____
Name or initials of contact person

Milan Soběslavský

Prague, 3.12.2007



Pavel Kudrna

Pavel Kudrna
Certification and Inspection Manager



ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV

Pod Lisem 129, 171 02 Praha 8 – Troja, Czech Republic



703402-01