

CCA - CENELEC Certification Agreement
Accord de Certification du CENELEC - CENELEC-Zertifizierung-Abkommen

NOTIFICATION OF TEST RESULTS

Product: Switch - disconnectors

Tested by request of: OBZOR, výrobní družstvo Zlín
 Na Slanici 378, 764 13 Zlín 4, Czech Republic

Manufacturer: OBZOR, výrobní družstvo Zlín
 Na Slanici 378, 764 13 Zlín 4, Czech Republic

Rating and principal characteristic: see enclosure - technical data for Switch disconnectors VSN 40, 63, 75

Trade name (if any):

Model/Type Ref.: VSN 40; 63; 75

Additional information (if any):

A sample of the product has been tested and found to be in conformity with the current HD/EN and equivalent national standard (number and edition):

EN 60947-1:04, EN 60947-3:99+A1:01+A2:05

as shown in the test report (reference No.): 704217-01/01 of: 17.01.2008

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provision of the relevant specific standard.

This Notification of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983. Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval, as specified in the CCA as long as the standard referred to above is still in force in the country of that body.

This Notification of Test Results may be challenged if it is more than three years old.

Internal ref.: ing. Milan Soběslavský
 Name or initials of contact person

Prague, 5.2.2008



Pavel Kudrna
 Certification and Inspection Manager



ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV

Pod Lisem 129, 171 02 Praha 8 – Troja, Czech Republic



704217-01